

2016 Tribal Lands and Environment Forum

Underground Storage Tanks

Mohegan

Connecticut

Program Updates

to

Eight Northern Indian Pueblos Council

Underground Storage Tank Program

New Mexico

Leonard Sabatino



Introduction

Leonard Sabatino



**Eight Northern Indian Pueblos Council, Inc.
Office of Environmental Technical Assistance
Underground Storage Tank Program
4 Years**

Originally from Philadelphia Pennsylvania

Geo-Environmental Studies 2001

9 years at the Los Alamos National Laboratory





19 pueblos

2 tribes

New Mexico, Region 6

**Served by ENIPC's
UST Program.**

**46 UST Facilities
within the external
boundaries of
tribal land.**



No New Installations, But lots of talk and lots of imagination.



Permanent Closure

Average about 1-2 every 5 years.
Contractor safety is a challenge.



Permanent Closure

How about a Safety Pause?!

Contractor's judgement can be questionable.



**Permanent Closure
Almost done.
Did anybody inert the tanks?**



Eight Northern Indian Pueblos Council Underground Storage Tank Program

**How we are assisting the tribal and
pueblo
UST facilities
in
NEW MEXICO
today.**



Compliance Assistance for Pueblos and Tribes in New Mexico.



What are we up to:

- *All assistance visits are on-site training visits that may take up to 7 Hours!**
- *Define the requirements for leak detection and leak prevention.**
- *Define the facility equipment.**
- *Communicate consistently.**
- *Have Patience. Lots of Patience.**
- *Follow up with reminders, due dates for line testing and corrosion protection testing.**



**Operating properly? Good record keeping?
Compliance? If not, check your email...**



Good morning,

Attached is the UST compliance assistance report for the [REDACTED]

Thank you for your attention during the compliance assistance training. The training sign in sheet is attached as well (last page).

I do have some recommendations, reminders and important information below associated with operations and maintenance, as well as compliance:

- 1) As a reminder, the line tightness tests and automatic line leak detector functionality tests will be due on or before 4/28/2016.
- 2) Recommend renewing the certificate of insurance, the certificate within the compliance assistance binder expired on 1/16/2016. Insurance for UST systems covers cleanups, property damage, and injuries from sudden and non-sudden accidental releases.
- 3) Recommend utilizing the new assistance binder to train new employees and train to the new UST regulations.
- 4) Keep up the good work with tank leak testing recordkeeping.
- 5) Recommend having a spill kit at the facility, a typical spill kit includes: a broom, absorbent material (kitty litter), water tight waste drum or trash can. Recommend the proper disposal of petroleum contaminated absorbent material.
- 6) Recommend conducting monthly walkthroughs and monitoring deliveries.
- 7) Recommend installing containment sumps beneath the dispensers to contain drips and leaks coming from within the dispenser above the ground surface.
- 8) As a reminder, corrosion protection testing for tanks and dispenser sumps will be due June 2017.

All of this information is on page 2 of the report.

I recommend reviewing the report, and print the report for the compliance assistance binder.

Please call me at the number below if you have any questions.

Keep up the good work.

COMPLIANCE ASSISTANCE REPORT FOR UNDERGROUND STORAGE TANKS



FACILITY NAME:

Date:

4-19-2016

ADDRESS: 462 North Riverside Drive

CITY: Espanola

STATE: NM

ZIP: 87532

COUNTY: Rio Arriba

FACILITY PHONE NUMBER: 505-747-8168

Facility
Operator Rep.
Contact:

Phone:

Cell: 901-8752

UST Owner:

Phone:

505-753-7330

Owner
Mailing:

Address: PO Box 580

City: Espanola

State: NM

Zip: 87532

PERSONNEL

Report By:

LEONARD SABATINO

Date:

4-19-2016

Time:

9AM

Representative
Signature:

Not Obtained

COMPLIANCE ASSISTANCE With Release Detection and Release Prevention.Has the facility met both Significant Operational Compliance Measures for Release **DETECTION** and Release **PREVENTION**: YES

Which compliance measure was not met: NA

Explanation for compliance measure not being met: NA

How the compliance measure not being met can be resolved: NA

Summary of Facility Monitoring Visit:

C-Store 2

- ① Spill Kit: Broom, Absorbent Material, TRASH CAN - Water tight.
- ② LINE TESTS: Reminder line testing due ON or before 4.28.16.
- ③ Insurance: Recommend Renewing Certificate, Expired 1.16.2016.
- ④ As a reminder, Corrosion Protection testing for tanks and dispenser SUMPS will be due JUNE 2017.
- ⑤ TANK LEAK Detection AND Record Keeping organization Looks great.
- ⑥ Recommend conducting Monthly WALKTHROUGHS AND Monitoring deliveries.
- ⑦ Recommend installing containment SUMPS beneath the dispensers to contain drips AND Leaks.

C-STORE 2


Facility ID #:
 FACILITY NAME:
 Owner ID#:

COMPLIANCE ASSISTANCE DATE(S):

SITE DRAWING:

Site Info:

- ① TANKS STIP3 - Single Wall
- ② Piping Fiberglass - Single Wall
- ③ Mechanical Line Leak Detector
- ④ Overfill Protection Flapper Valves
- ⑤ ATG INCOITS 1001
- ⑥ 12 DISPENSERS w/ UNCONTAINED SUMPS
- ⑦ CORROSION Protection Testing required in dispenser SUMPS AND TANKS Every 3 years.



402 Riverside Drive

FACILITY NAME:

Date:

4-19-2016

Underground Storage Tanks Listed Below have been Registered with the Federal EPA

TANK NO.	SIZE OF TANK (GALLONS)	PRODUCT STORED	TANK TYPE	STATUS Active or TC	INSTALL DATE	UPGRADE DATE
1	10,000	REGULAR	Coated	Active	9/1994	
2	10,000	REGULAR	AND		9/1994	
3	10,000	PREMIUM	Cathodically PROTECTED Steel STE-P3	↓	9/1994	

TANK TYPE ☒ Single Wall ☐ Double Wall:

Single Wall STE-P3

1. Proper design and construction to prevent corrosion? Fiberglass, Metal, or Clad(ACT-100), STE-P3 S-P8

☒ Yes ☐ No ☐ N/A

EXISTING TANKS: UPGRADES (Tanks installed on or before 12/22/88)

PREVENTION

☐ Single Wall ☐ Double Wall Tank Type:

1. Existing tanks upgraded to meet standards for new UST systems? S-P8

☐ Yes ☐ No ☒ N/A

a. Metal Tank w/ lining. Date liner was installed:

S-P7/8

☐ Yes ☐ No ☒ N/A

b. Metal tank with CP. Type of CP:

>10 yrs old CP added? Integrity Test and Date?

S-P8

☐ Yes ☐ No ☒ N/APIPING TYPE ☒ Single Wall ☐ Double Wall:

Single Wall Fiberglass Reinforced Plastic

1. Proper design and construction to prevent corrosion? Fiberglass, Non-metallic Flex, Metalw/CP S-P8

☒ Yes ☐ No ☐ N/A

2. Metal components(flexible connectors, submersible turbine pumps)Protected from Corrosion?How? S-P8

Anodes

3. Are all impact valves/shear valves properly installed (moving parts unobstructed, shear valve properly anchored)? (NEPA 30A Chapter 6 Paragraph 3.9) (New & Existing Systems-pressurized)

☒ Yes ☐ No ☐ N/A

1. Is each tank equipped with Spill Prevention Equipment? S-P1

☒ Yes ☐ No ☐ N/A

Spill Prevention equipment has liquid tight sides and bottom (not cracked or broken)? S-P1

☒ Yes ☐ No ☐ N/A

1. Is each tank equipped with Overfill Prevention Equipment? S-P2

☒ Yes ☐ No ☐ N/A

2. Overfill Prevention Equipment designed to: (Shutoff Restrict Alarm S-P2

☒ Yes ☐ No ☐ N/A

Automatic flow shut off when the tank is no more than 95% full? (device not tampered with or inoperable)

☒ Yes ☐ No ☐ N/A

Alert the transfer operator when the tank is 90 % full by restricting flow into the tank-ball float valve.

☐ Yes ☐ No ☒ N/A

Alert the transfer operator when the tank is 90% full triggering an overfill alarm near the fill port? Work?

☐ Yes ☐ No ☒ N/A

OPERATION and MAINTENANCE of CORROSION PROTECTION SYSTEMS

PREVENTION

1. Is the corrosion protection system continuously operated and maintained S-P5

☒ Yes ☐ No ☐ N/A

2. Are the cathodic protection systems inspected by qualified testers? S-P5

☒ Yes ☐ No ☐ N/A

3. Was the cathodic protection system tested within 6 months after installation? Date: ? S-P4

☐ Yes ☐ No ☐ N/A

4. Is the system tested at least every 3 years? Dates: 2010, 6-2014 S-P5

☒ Yes ☐ No ☐ N/A5. Inspection meet the requirements of a code of practice developed by a nationally recognized association? ☒ Yes ☐ No ☐ N/A6. Does the facility have copies of the last 2 CP inspections? ☒ Yes ☐ No ☐ N/A

7. If the UST system has an impressed current, is the rectifier inspected every 60 days? S-P6

☐ Yes ☐ No ☒ N/A8. As outlined in EPA regulations, does the facility have copies of the last 3 rectifier inspections? ☐ Yes ☐ No ☒ N/A9. Are all records of UST system repairs retained for the operating life of the UST system? ☐ Yes ☐ No ☒ N/A

a. Is a tightness test performed on the tank and/or piping within 30 days of a repair? S-P3

☐ Yes ☐ No ☒ N/A

b. Is the cathodic protection system tested within 6 months of a repair? S-P4

☐ Yes ☐ No ☒ N/A

FACILITY NAME: C-S + 2

Date: 4-19-2016

Requirements for Tank Leak Testing

DETECTION

- | | | |
|--|-------------|--|
| 1. Does the facility perform a method of release detection? Check "No" if no RD conducted | S-D1 | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| 2. Is the method of release detection capable of detecting a release from any portion of the tank? | S-D2 | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| 3. Is the release detection system installed, calibrated, operated, and maintained in accordance with the manufacturer's instructions including routine maintenance, etc.? | S-D3 | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| 4. Does the release detection system meet the performance standards? Check 3rd party certification. | S-D3 | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| 5. Are all USTs monitored at least every 30 days for releases? | S-D5 | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |

Requirement for Tank Leak Testing Record Keeping

DETECTION

- | | | |
|---|-------------|--|
| 1. Does the facility maintain all monitoring results, sampling records, equipment testing, calibration and maintenance records, or leak detection equipment repair records for at least one year? | S-D5 | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
|---|-------------|--|

RELEASE REPORTING, INVESTIGATION, and CONFIRMATION

DETECTION

SUSPECTED RELEASES: Report unusual operating conditions, failed tests, product discovery

- | | | |
|--|-------------|--|
| 1. When a release detection method indicates that a release may have occurred; has the facility notified EPA of a suspected release? | S-D4 | <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A |
| 2. Facility has resolved suspected releases? | S-D4 | <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A |

SPILLS and OVERFILLS: Report >25 gals, <25 gals can't be cleaned up in 24 hrs, sheen H2O

☐ Yes ☐ No ☒ N/A

TANKS RELEASE DETECTION/LEAK TESTING METHODS

DETECTION

☒ 1. Automatic Tank Gauging (ATG)

S-D5

Make and Model: INCON TS 1001

- | | | |
|---|-------------|--|
| a. Is the ATG capable of detecting a leak of 0.2 gal/hr leak rate? | S-D3 | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| b. As the sole method of release detection, the ATG must test the tank at least once per month in a manner that can detect a 0.2 gal/hr release with a pd > 0.95 and a pfa < 0.05 | S-D3 | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| c. The ATG will generate a hard copy which contains the following: | | |
| i. the time and date of the test | | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| ii. the tank identification | | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| iii. the qualitative result either "pass" or "fail" | | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |

☐ 2. Interstitial Monitoring

S-D5

Describe the UST system which is in doubt: double walled tank, secondary barrier?

Can the method detect a release from the inner wall of the tank? **S-D2** ☐ Yes ☐ No ☐ N/A

Continuous interstitial monitoring by an automatic leak sensing device that signals to the operator the presence of any regulated substance in the interstitial space or sump: Specify: ☐ Yes ☐ No ☐ N/A

☐ 3. Statistical Inventory Reconciliation (SIR)

S-D5

- | | | |
|---|-------------|---|
| a. Can the SIR method detect a release of 0.2 gal/hr from any portion of the UST System that contains product with a pd > 0.95 and a pfa < 0.05? | S-D3 | <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| b. Did the owner/operator receive the monthly report from the SIR provider/vendor within 15 days following the last day of the calendar month for which the analysis was performed? | | <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| c. Did the SIR analysis report include the following information? | | |
| i. the name of the SIR provider and the name and version of the SIR method; | | <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| ii. the name and address of the facility at which the analysis was performed; | | <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| iii. a description of the UST system for which the analysis was performed; | | <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| iv. a quantitative statement, in gallons/hr, for each UST system monitored for the month, of the leak threshold, minimum detectable leak rate, and the indicated leak rate; | | <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |
| v. a qualitative statement of "pass," "fail," or "inconclusive" for each UST system monitored | | <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A |

Notes with regards to SOC Release Detection: REMINDER FOR LINE TESTING

Water in Tank: NONE

Alarm Status: NONE

FACILITY NAME: [REDACTED]

ENTER

Date: 4.9.2016

PIPING RELEASE DETECTION/LEAK TESTING

DETECTION

1. **Pressurized Piping:** Is release detection performed on the UST system's piping **S-D1** ☒ Yes ☐ No ☐ N/A
Automatic Line Leak Detectors (ALLD) installed (one of the following methods is required on all pressurized lines, regardless of line leak detection method used) **S-D5** ☒ Yes ☐ No ☐ N/A

TYPE of Line Leak Detectors: MECHANICAL OR ELECTRONIC MODEL: Red Jacket Vapor Less FE PETRO

1. Automatic flow restrictor-MECHANICAL

*Is a performance test conducted every 12 months on the line leak detector according to manufacturer's requirements?

Previous Testing Dates: 2-2014
Most Recent Test Date: 4-28-2015

AND

*A line tightness test conducted every 12 months?

Previous Testing Dates: 2-2014
Most Recent test Date: 4-28-2015

Is LTT method capable of detecting a 0.1 gal/hr leak rate from any portion of the piping routinely containing product? **S-D3** ☒ Yes ☐ No ☐ N/A

2. Automatic shutoff, Alarm-ELECTRONIC

*3 gal/hr test printed from ATG with a result of PASS

AND

*0.1 test printed from ATG with a result of PASS OR Monthly 0.2 test with a result of PASS **S-D5** ☐ Yes ☐ No ☒ N/A

TEMPORARY CLOSURE

DETECTION

If greater than 1 inch of liquid remains, is monthly release detection completed? **S-D7** ☐ Yes ☐ No ☒ N/A

If applicable, is the Cathodic Protection being maintained? **S-D5** ☐ Yes ☐ No ☒ N/A

2. For UST systems temporarily closed for 3 months or more, did the owner/operator:

Leave vent line open and functional? ☐ Yes ☐ No ☒ N/A

Cap and secure all other lines, pump, manways, etc. equipment? ☐ Yes ☐ No ☒ N/A

3. For any non-upgraded UST system temporarily closed for more than 3 months, did the owner/operator permanently close the system? ☐ Yes ☐ No ☒ N/A

Additional Record Keeping

EPA Notification Form/Registration form -current and accurate? -On site? -Amended for acquiring a UST? ☒ Yes ☐ No ☐ NA

-Amended change in Service? -Ownership change? -Installer certification? Permanent Closure? Temp. Closure? ☐ Yes ☐ No ☒ NA

Reports of all releases-suspected releases- spills and overfills-confirmed releases? ☐ Yes ☐ No ☒ NA

Corrective Actions-Descriptions of corrective action plans, site characterizations, free product removal investigation of soil and groundwater cleanup, and corrective action plan? ☐ Yes ☐ No ☒ NA

Site Assessments-Results of site assessment conducted at permanent closure? ☐ Yes ☐ No ☒ NA

Repairs-Documentation of UST system repairs? Maintain documentation for the life of the UST System. ☐ Yes ☐ No ☒ NA

Installation Records-Documentation of the type and construction of the tanks, piping, leak detection equipment, corrosion protection equipment, and spill and overfill protection equipment? ☐ Yes ☐ No ☒ NA

INSURANCE: Current Certificate and Certification of Financial Responsibility

1. Can the owner/operators demonstrate financial responsibility/Insurance for taking corrective action (Cleanups), and 3rd party liability (property damage and injuries)? YES

Dates of Coverage: 1-16-2016 Expired

Insurance Company: ACE

Typical Owner/Operator ENIPC Training AGENDA

- **Welcome, Introductions and Purpose.**
- **UST Program Overview.**
- **UST Program Definitions.**
- **UST Systems: Tanks, Piping, and Sump Areas.**
- **Submersible Turbine Pumps.**
- **Dispensers.**
- **Underground Storage Tank Federal Regulations and Requirements.**
- **UST Program Scope.**
- **UST System: Design, Construction, Installation and Notification.**
- **General Operating Requirements.**
- **Leak Testing/Release Detection.**
- **Release Reporting, Investigation and Confirmation.**
- **Release Response and Corrective Action for UST Systems.**
- **Out of Service UST Systems and UST Facility Closure.**
- **Financial Responsibility.**
- **NEW UST Regulations. Safety. Site Walk Through and Evaluation.**



Owner/Operator Training

Average number of participants: 15-25.



1-3 Owner/Operator Trainings per year.



Owner/Operator Training Incorporate a Site Walkthrough.



Identifying Equipment.






Every Facility is Unique



K1000

Site Info

- ① Tanks Single Wall ACT-100.
- ② Tanks 4, 5, 6 are manifolded.
- ③ Overfill Protection on all.
- ④ Mechanical line leak Detectors
- ⑤ Piping: FRP Single Wall - 1, 2, 3 Double Wall - 4, 5, 6, 7
- ⑥ Sump Sensors are located in Truck Diesel Dispensers and Diesel STPs
- ⑦ Warren Rogers SIR AND INCON





Product Flow?

Product Lines from Diesel Tanks 4, 5, 6, 7 to form one Line.

Truck Diesel Side

Auto Side




Dispensers = 20





3.24.2015

TRAVEL PLAZA






Tank pad next to dispensers, where traffic flows=



Site DRAWING

HWY 550



CONVENIENCE STORE

CONVENIENCE STORE



Tanks away from traffic flow= 😊


Facility ID #: [REDACTED]

Owner ID#: [REDACTED]


ANCE ASSISTANCE

2.3.2015

SITE DRAWING:



CONVENIENCE STORE



Requirements for Leak Detection

① TANKS: Interstitial Monitor Every 30 Days or CSLD

② Lines/Piping: Every 30 Days PLD 0.2 gal/hr empty space, ullage and Product

- ① FRPDW TANKS
- ② Install DATE: 8.2007
- ③ NonFlex Piping NonMetallic
- ④ Electronic Line Leak Detectors



Tank Manifolding

2 Compartment Tank mani-folded to 2 compartments of a 3 compartment tank. 2-Interstitial Monitors provide leak detection for all 5 tanks.





**Double-Walled STI-P3 Tanks. Interstitial Monitoring,
installation 1998.**

Mechanical Line leak Detectors.





Contractors Didn't Install Interstitial Monitoring!

**Double Walled Clad Tanks and Double walled FRP piping.
Ball Float overfill protection. Electronic Line leak detectors.**

**Triple compartment and Double Compartment tanks = 5
Tanks.**



**Every Facility is unique, challenging,
interesting, and in need of a lot of
assistance!**



Leonard Sabatino
Isabatino@enipc.org

505-692-8772

Questions?

Thank you EPA, tribes and pueblos!

